



IECEX Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

| | | | |
|---------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------|-----------------------------|
| Certificate No.: | IECEX BVS 10.0043X | Page 1 of 4 | <u>Certificate history:</u> |
| Status: | Current | Issue No: 7 | Issue 6 (2024-05-21) |
| Date of Issue: | 2024-07-31 | | Issue 5 (2021-03-10) |
| Applicant: | MSA EUROPE GmbH Schlüsselstraße 12 8645 Rapperswil-Jona Switzerland | | Issue 4 (2016-07-04) |
| Equipment: | Gas Detector type PrimaX I and PrimaX P | | Issue 3 (2013-06-19) |
| Optional accessory: | | | Issue 2 (2012-05-02) |
| Type of Protection: | Equipment protection by flameproof enclosures "d", Equipment protection by intrinsic safety "i", Equipment dust ignition protection by enclosure "t" | | |
| Marking: | Ex ia IIC T4 Ga | for PrimaX I | Issue 1 (2011-03-25) |
| | Ex db ia [ia] IIC T4/T6 Gb | | Issue 0 (2010-05-18) |
| | Ex tb ia [ia] III C T130°C/T85°C Db | for PrimaX P | |

Approved for issue on behalf of the IECEx
Certification Body:

Dr Franz Eickhoff

Position:

**Senior Lead Auditor, Certification Manager and officially
recognised expert**

Signature:
(for printed version)


2024-07-31

Date:
(for printed version)

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting www.iecex.com or use of this QR Code.



Certificate issued by:

DEKRA Testing and Certification GmbH
Certification Body
Dinnendahlstrasse 9
44809 Bochum
Germany





IECEX Certificate of Conformity

Certificate No.: **IECEX BVS 10.0043X**

Page 2 of 4

Date of issue: 2024-07-31

Issue No: 7

Manufacturer: **MSA (China) Safety Equipment Co., Ltd.**
No. 8 Rui En Lane, Xingpu Road
Suzhou Industrial Park, Jiangsu
China

Manufacturing locations: **MSA (China) Safety Equipment Co., Ltd.**
No. 8 Rui En Lane, Xingpu Road
Suzhou Industrial Park, Jiangsu
China

General Monitors Ireland Ltd
Ballybrit Business Park
Galway
Ireland

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEX Quality system requirements. This certificate is granted subject to the conditions as set out in IECEX Scheme Rules, IECEX 02 and Operational Documents as amended

STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

[IEC 60079-0:2017](#) Explosive atmospheres - Part 0: Equipment - General requirements
Edition:7.0

[IEC 60079-1:2014](#) Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d"
Edition:7.0

[IEC 60079-11:2011](#) Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"
Edition:6.0

[IEC 60079-31:2022](#) Explosive atmospheres – Part 31: Equipment dust ignition protection by enclosure "t"
Edition:3.0

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Report:

[DE/BVS/ExTR10.0063/06](#)

Quality Assessment Reports:

[DE/BVS/QAR10.0012/10](#)

[GB/CML/QAR22.0009/01](#)



IECEX Certificate of Conformity

Certificate No.: **IECEX BVS 10.0043X**

Page 3 of 4

Date of issue: 2024-07-31

Issue No: 7

EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

Gas detector type PrimaX I:

The device type PrimaX I is a stationary gas detector for the measurement of oxygen or toxic gases in ambient air under atmospheric conditions. The gas detector contains one electrochemical sensor for gas measurement (PrimaX Ox-Tox Sensor).

The gas detector type PrimaX I is designed with an antistatic plastic housing. The surface resistance of the housing is $\leq 10^9 \text{ W}$.

The housing is mounted to a plastic mounting bracket which can be pre mounted before the PrimaX I will be connected to the mounting bracket. The surface resistance of the mounting bracket is $\leq 10^9 \text{ W}$, too.

The 2-wire connection to the gas detector type PrimaX I is done via a M25 cable gland.

As an option, the gas detector type PrimaX I contains a HART - module. The connection to an external HART - Handheld Controller can be done by a special HART - plug-in connector.

Gas detector type PrimaX P:

The device type PrimaX P is a stationary gas detector for the measurement of combustible, oxygen or toxic gases in ambient air under atmospheric conditions.

The gas detector contains, depending on construction, one changeable intrinsically safe electrochemical sensor (PrimaX Ox-Tox Sensor) or one sensor in type of protection Flameproof Enclosure (PrimaX Ex Sensor) for gas measurement.

The connection to the non-intrinsically safe power supply-/signal circuit is done via a cable gland (d).

As an option, the gas detector type PrimaX P contains a HART - modul. The connection to an external intrinsically safe HART - Handheld Controller can be done by a special HART - plug-in connector.

Ratings

See Annex

Marking

See Annex

SPECIFIC CONDITIONS OF USE: YES as shown below:

For Gas Detector PrimaX I and PrimaX P:

The measuring function for explosion protection is not subject of this Certificate.

Avoid electrostatic charge on the temporary used calibration cap when used for calibration.

For Gas Detector PrimaX I:

It is not allowed to open the key pad cover during usage in areas where EPL Ga, Group IIC is required.

For Gas Detector PrimaX P:

The joint widths of the flameproof joint of this apparatus are in parts longer, and its gaps are in parts shorter than the values of Table 3 of IEC 60079-1:2014. For maintenance or repair contact the manufacturer.

Intensive electrostatic charging processes to the instrument label have to be prevented.

In case of using the **PrimaX Ex-Sensor**, the complete device type **PrimaX P** is in accordance to temperature class T6/T85 °C, ambient temperature range $-40 \text{ °C} \leq T_a \leq +40 \text{ °C}$ or to temperature class T4/T130 °C, ambient temperature range $-40 \text{ °C} \leq T_a \leq +70 \text{ °C}$.

In case of using the **PrimaX Ox-Tox-Sensor**, the complete device type **PrimaX P** is in accordance to temperature class T4/T130 °C, ambient temperature range $-40 \text{ °C} \leq T_a \leq +70 \text{ °C}$.



IECEX Certificate of Conformity

Certificate No.: **IECEX BVS 10.0043X**

Page 4 of 4

Date of issue: 2024-07-31

Issue No: 7

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above)

Update to the current status of standards.

Dust approval for PrimaX I has been withdrawn.

Electronic circuit slightly modified.

Minor changes to the enclosure.

Option: Sensor MSA XCell XXX (IECEX FTZU 09.0024U) removed.

Annex:

[BVS_10_0043X_MSA Europe_Annex_issue7.pdf](#)



IECEX Certificate of Conformity



Certificate No.: IECEX BVS 10.0043X issue No: 7
Annex
Page 1 of 2

Ratings for Gas detector type PrimaX I:

Intrinsically safe power supply-/signal circuit, connection via a M25 cable gland and 2 internal plug-in terminals:

| | | | | |
|------------------------------|-------|----|-----|------------|
| Maximum input voltage | U_i | DC | 28 | V |
| Maximum input current | I_i | | 100 | mA |
| Maximum input power | P_i | | 700 | mW |
| Maximum internal capacity | C_i | | | negligible |
| Maximum internal inductivity | L_i | | | negligible |

Optional intrinsically safe HART - connector, connection via plug-in connector. Only for a temporary connection of an intrinsically safe HART - Handheld Controller.

| | | | | |
|------------------------------|-------|----|-----|------------|
| Maximum output voltage | U_o | DC | 28 | V |
| Maximum output current | I_o | | 100 | mA |
| Maximum output power | P_o | | 700 | mW |
| Maximum external capacity | C_o | | 1 | nF |
| Maximum external inductivity | L_o | | 10 | μ H |
| Maximum input voltage | U_i | DC | 5 | V |
| Maximum input current | I_i | | 1 | mA |
| Maximum input power | P_i | | 5 | mW |
| Maximum internal capacity | C_i | | | negligible |
| Maximum internal inductivity | L_i | | | negligible |

Ambient temperature range (**Ex ia IIC T4 Ga**): $-40\text{ }^{\circ}\text{C} \leq T_a \leq +70\text{ }^{\circ}\text{C}$

Ratings for Gas detector type PrimaX P:

Non intrinsically safe power supply-/signal circuit, connection via a cable gland (d) and internal 4-Pin plug-in-terminal.

| | | | | |
|-----------------------|-----------|----|----|---|
| Nominal voltage | U_{max} | | 30 | V |
| Maximum input voltage | U_m | DC | 60 | V |

Optional non intrinsically safe relays contact circuit, connection via a cable gland (d) and 2 internal 3-Pin-plug-in-terminals (changeover-relays contacts).

| | | | | |
|---------------------------|--|----|----|---|
| Maximum switching voltage | | DC | 30 | V |
| Maximum switching current | | | 2 | A |

Optional intrinsically safe HART - circuit, connection via plug-in connector. Only for a temporary connection of an intrinsically safe HART - Handheld Controller.

| | | | | |
|------------------------------|-------|--|-----|------------|
| Maximum output voltage | U_o | | 2.7 | V |
| Maximum output current | I_o | | 137 | mA |
| Maximum output power | P_o | | 185 | mW |
| Maximum external capacity | C_o | | 1 | nF |
| Maximum external inductivity | L_o | | 10 | μ H |
| Maximum input voltage | U_i | | 5 | V |
| Maximum input current | I_i | | 1 | mA |
| Maximum input power | P_i | | 5 | mW |
| Maximum internal capacity | C_i | | | negligible |
| Maximum internal inductivity | L_i | | | negligible |

Ambient temperature range

T4/T130 $^{\circ}\text{C}$: $-40\text{ }^{\circ}\text{C}$ up to $+70\text{ }^{\circ}\text{C}$

T6/T85 $^{\circ}\text{C}$: $-40\text{ }^{\circ}\text{C}$ up to $+40\text{ }^{\circ}\text{C}$

See additional "Conditions of Use" for Ex Equipment.



IECEX Certificate of Conformity



Certificate No.: IECEX BVS 10.0043X issue No: 7
Annex
Page 2 of 2

Marking PrimaX I:

Name and address of the manufacturer

Type PrimaX I

Ex ia IIC T4 Ga

$-40\text{ °C} \leq T_a \leq +70\text{ °C}$

Serial number

Certification number

Marking PrimaX P Main housing:

Name and address of the manufacturer

Type PrimaX P

Ex db ia [ia] IIC T4/T6 Gb

Ex tb ia [ia] IIIC T130°C/T85°C Db

T4/T130 °C $-40\text{ °C} \leq T_a \leq +70\text{ °C}$

T6/T85 °C $-40\text{ °C} \leq T_a \leq +40\text{ °C}$

Serial number

Certification number

Marking PrimaX Ex-Sensor:

Name and address of the manufacturer

Type PrimaX Ex Sensor

Ex db IIC T4/T6 Gb

Ex tb IIIC T130°C/T85°C Db

T4/T130 °C $-40\text{ °C} \leq T_a \leq +70\text{ °C}$

T6/T85 °C $-40\text{ °C} \leq T_a \leq +40\text{ °C}$

Serial number

Marking PrimaX Ox-Tox-Sensor:

Name and address of the manufacturer

Type PrimaX Ox-Tox Sensor

Ex ia IIC T4 Ga

Ex ia IIIC T135°C Db

$-40\text{ °C} \leq T_a \leq +70\text{ °C}$

Serial number